EXISTING PANEL L3B SECT. 1

RATING 400 AMP M.L.O.
SERVICE 120/208V, 3ø, 4W
LUG LOCATION BOTTOM
MOUNTING SURFACE
A.I.C. 22K
TYPE EXISTING

CKT NO	EQUIPMENT SERVED	KVA	CKT. BKR. POLE	CKT. BKR. TR	BRANCH CIRCUIT ø	BRANCH CIRCUIT NEUT	BRANCH CIRCUIT GND	BRANCH CIRCUIT COND	ø	CKT. NO.	EQUIPMENT SERVED	KVA	CKT. BKR. POLE	CKT. BKR. TR	BRANCH CIRCUIT ø	BRANCH CIRCUIT NEUT	BRANCH CIRCUIT GND	BRANCH CIRCUIT COND
1	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	A	2	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
3	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	4	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
5	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	C	6	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"
7	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	A	8	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
9	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	10	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
11	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	C	12	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
13	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"	A	14	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
15	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	16	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
17	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"	C	18	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
19	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	A	20	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"
21	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	22	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"
23	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	C	24	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
25	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	A	26	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
27	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	28	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
29	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"	C	30	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
									A	32	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
33	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"	B	34	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
35	NEW WORKSTATIONS	1.08	1	20	12	12	12	1/2"	C	36	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
37	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	A	38	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
39	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	B	40	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.
41	EXISTING		EXIST.		EXIST.	EXIST.	EXIST.	EXIST.	C	42	EXISTING		EXIST.			EXIST.	EXIST.	EXIST.

NEW WORK — CKT 13
NEW WORK — CKT 29
NEW WORK — CKT 33, CKT 35
NEW WORK — CKT 6
NEW WORK — CKT 20, CKT 22

EQUIPMENT SERVED	CONN. LOAD	LF	DF	DESIGN LOAD (KVA)	REMARKS
NO NEW LOAD IS BEING ADDED TO THIS PANEL					
			TOTAL		
			SPARE		42 CIRCUITS

- UPDATE PANEL DIRECTORY
- ALL WORK INVOLVING THIS PANEL CONSISTS OF RECONNECTING EXISTING CIRCUIT BREAKERS TO NEW POWER RECEPTACLES